

Lindab UltraLink® Controller FTCU

Mounting instruction



For installation video, click here >>

Please note:

- Do not remove the transducers!
- Do not use transducers as handles when you mount the FTCU since this may cause damage!



 Make sure the airflow arrow is pointing in the direction of the airflow.



- Rotate the senor body to the correct position according to next page.
- On FTCU's sizes 400 630 loosen the nut so the sensor body can be turned into the desired position. The flange must then be fastened by tightening the nut.



• Position the display so it is visible from a suitable direction.




 Mount the FTCU into the air duct system according to the mounting instructions for Lindab Safe.




 When the FTCU is positioned accurately it should be fixed with screws to the damper body in the same way as when you connect ducts and fittings.




- Never use a FTCU on the outlet side of a duct fan. Place it on the inlet side or in worst case use a flow conditioner if it must be placed on the outlet side.
- The longer distance to disturbance, i.e. the longer straight duct before the UltraLink®, the higher the measurement accuracy will be.



- Note the ID-number of the FTCU. The ID is the three last numbers of the serial number and can be found:
 - on the label of the box it was delivered in
 - on the label on the FTCU itself
 - in the display after pressing the "MODE" button
 - in the App when the product is on
- The motor direction switch must always be set to "1" as supplied.







Please note:


 If the damper needs to be turned manually, then press the manual override button on the motor and turn the damper shaft with a 8 mm wrench or similar.




 To avoid issues with measurement accuracy due to air turbulence:

Make sure you never install a measurement unit after (in airflow direction) two disturbance fittings (refering to number 1 and 2) where those two fittings are installed in two different levels and the airflow also turnes in cross direction. (Refering to number 3)

Not following these rules the measurement might not be accurate due to air turbulance.





Positioning

Disturbance	* Placement of first flow sensor		Measurement uncertainty ± % or X I/s depending wich is the greatest*		
			2-4רd	>4-5רd	>5רd
Bend		Inner radius (Best position)	5	5	5
T-piece	a e e e e e e e e e e e e e e e e e e e	Inner radius (Best position)	10	5	5
Reducer	a a a a a a a a a a a a a a a a a a a	Duct diameter decrease	5	5	5
Reducer	a a contract of the contract o	Duct diameter increase	10	5	5

^{*} ± 5 % or l/s (Ø100 = $\pm 1,00$, Ø125 = $\pm 1,25$, Ø160 = $\pm 1,60$, Ø200 = $\pm 2,00$, Ø250 = $\pm 2,50$, Ø315 = $\pm 3,15$, Ø400 = $\pm 4,00$, Ø500 = $\pm 5,00$, Ø630 = $\pm 6,30$)





Declaration of incorporation for partly completed machinery and FCC statement

macrimory and 1 00 statement				
Declaration number	1002			
2. Unique identification code of the product	FTCU			
3. Type	Ultrasonic device			
4. Product description	Measuring and controlling air flow and measuring temperature			
5. Manufacturer	Lindab Ventilation AB Stålhögavägen 115, 26982 Båstad, Sweden			
	Telephone +46 431 85000, www.lindab.com			

Developed, designed and ma Regulation(s):	anufactured with the essential re	equirements by safe and security of the European Directive(s) and	
2006/42/EC 1.1.2, 1.1.3, 1.3.4	Machinery Directive (MD)	Partly completed machinery must not be put into service until the final machinery into which it is to be incorporated has been declared in conformity with the provisions of the Machinery directive 2006/42/EC. We undertake to transmit, in response to a request by the national authorities, relevant information on the product.	
2014/30/EU	Electromagnetic Compatibility Directive (EMC)		
2011/65/EU & 2015/863/EC	Restriction of Hazardous Sub	ostances (RoHS)	

The partly completed machinery is developed, designed and manufactured with the essential requirements of the following standards:				
EN 61000-6-1:2002 - Part 6-1	Generic standards - Immunity for residential, commercial and light-industrial environments			
EN 61000-6-2:2005 - Part 6-2	Generic standards - Immunity for industrial environments			
EN 61000-6-3:2002 - Part 6-3	Generic standards - Emission standard for residential, commercial and light-industrial environments			
EN 61000-6-4:2002 - Part 6-4	Generic standards - Emission standard for industrial environments			

FCC cuation and statement

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation. Changes or modifications not expressly approved by the part responsible for compliance could void the user's authority to operate the equipment. This equipment complies with FCC exposure limits set forth for an uncontrolled environment.

"This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help."

This declaration of conformity is established under the sole responsibility of the manufacturer identified in point 5.

Signed for and on behalf of the manufacturers by:

Authorised person: Karel Kleinmond

Group Operations Director

2021-01-18 Karlovarska, Czech Repulic

